



WAUKESHA-PEARCE, IND.

Official Load Test Report

713-551-0470 Office - 713-551-0590 Fax
281- 537-4674 After Hours

W. O. No.	84995
Cust. PO No.	

Date of Service 8/2/2018	Unit MN: SG0250KG13133N23HPYYE	Unit SN: 2113795	Unit Spec:
Bill To Acct. Name Swift Equipment	Engine MN: 13.3 HINO	Engine SN: N/A	Engine Spec: N/A
Ship To Acct. Name	Transfer Sw. MN: N/A	Transfer Sw SN: N/A	Transfer Sw. MFG/Spec: N/A
Address 7946 RAND ST	Generator KW 250	Phase 3	Volts 208
City HOUSTON	ST TX	Zip 77028	HR MTR START 0.3
Site Contact # 832-457-0976	Type Of Service Load Test	Equip. MFG GENERAC	HR MTR STOP 1.3
Site Contact Name JOSH KRAMER	Site Contact email	Engine MFG HINO	Unit Location Description: CUSTOMER YARD
		Cable Length 50'	Application STANDBY
		Test Type Loadbank	Test Results Pass

	CLOCK TIME	RUN TIME	VOLTS			AMPS			PF %	KW	LOAD %	FREQ Hz	PRESSURE		Eng. Temp °F	AMB Temp °F	HOUR METER	GAS PRESS
			A-B	B-C	A-C	A	B	C					OIL	FUEL				
1	1:15	0:00	208	208	208	175	174	171	1.0	62	25%	60.0	81	NA	176		0.3	13.5
2	1:30	0:15	208	208	208	175	173	170	1.0	62	25%	60.0	77	NA	176		0.6	13.5
3	1:45	0:30	208	208	208	348	345	345	1.0	125	50%	60.0	74	NA	176		0.8	13.5
4	2:00	0:45	208	208	208	571	570	570	1.0	205	82%	60.0	71	NA	179		1	13.5
5	2:15	1:00	208	208	208	701	699	699	1.0	252	101%	60.0	69	NA	181		1.3	13.5
6	2:30	1:15	208	208	208	0	0	0	1.0			60.0	75	NA	174		1.3	13.8
7	2:45	1:30																
8	3:00	1:45																
9	3:15	2:00																
10	3:30	2:15																
11	3:45	2:30																
12	4:00	2:45																
13	4:15	3:00																
14	4:30	3:15																
15	4:45	3:30																
16	5:00	3:45																
17	5:15	4:00																
18	5:30	4:15																
19	5:45	4:30																
20	6:00	4:45																

Notes

Abraham Gamboa **2040**

Technicians Signature

Payroll ID

Customer Print

Customer Signature